

Fern Place School

Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Executive Directors Bathroom	Bathroom Faucet	Non-Potable	10/10/2020	100	Placarded for Non-Drinking Use Until Remediated

Mattlin Middle School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Kitchen Room A1/A2	Pasta Pot/Steam Kettle	Potable	9/24/2020	1000	Removed from Service, Pending Remediation
Storage A5	Hand Wash Only	Non-Potable	9/24/2020	79	Placarded for Non-Drinking Use Until Remediated
PTA Storage A3	Kitchen Faucet (Cold)	Potable	9/24/2020	1400	Removed from Service, Pending Remediation
Family & Consumer Sciences Room A2	Home Economics Faucet (Cold)	Potable	9/24/2020	630	Removed from Service, Pending Remediation
Family & Consumer Sciences Room A2	Home Economics Faucet (Cold)	Potable	9/24/2020	76	Removed from Service, Pending Remediation
Pal Room (Former Nurses Office)	Hand Wash Only	Non-Potable	9/24/2020	30	Placarded for Non-Drinking Use Until Remediated
Girls Locker Room Bathroom 2	Bathroom Faucet	Non-Potable	9/24/2020	20	Placarded for Non-Drinking Use Until Remediated
Girls Coach Office Bathroom	Bathroom Faucet	Non-Potable	9/24/2020	24	Placarded for Non-Drinking Use Until Remediated
Music Room B Storage	Classroom Faucet	Non-Potable	9/24/2020	3600	Placarded for Non-Drinking Use Until Remediated
Family & Consumer Sciences Room A1	Home Economics Faucet (Cold)	Potable	9/23/2020	700	Removed from Service, Pending Remediation
Server Room Across from D 2-A	Hand Wash Only	Non-Potable	9/23/2020	60	Placarded for Non-Drinking Use Until Remediated
Science Prep	Hand Wash Only	Non-Potable	9/23/2020	160	Placarded for Non-Drinking Use Until Remediated
Room C 7	Home Economics Faucet (Cold)	Potable	9/23/2020	120	Removed from Service, Pending Remediation

Mattlin Middle School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Room D 7 Rear Storage Room	Hand Wash Only	Non-Potable	9/23/2020	180	Placarded for Non-Drinking Use Until Remediated
Room D 21	Classroom Faucet	Non-Potable	9/23/2020	170	Placarded for Non-Drinking Use Until Remediated

Jamaica Avenue School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Corridor Room 200 To 203	Water Fountain-No Chiller	Potable	10/10/2020	140	Removed from Service, Pending Remediation
Gym Corridor	Water Fountain-No Chiller	Potable	10/10/2020	25	Removed from Service, Pending Remediation
Men's/Women's Bathroom	Bathroom Faucet	Non-Potable	10/10/2020	21	Placarded for Non-Drinking Use Until Remediated
Kitchen	Hand Wash Only	Non-Potable	10/10/2020	140	Placarded for Non-Drinking Use Until Remediated
Corridor Outside Red Room 105	Water Fountain-No Chiller	Potable	10/10/2020	25	Removed from Service, Pending Remediation
Room 213	Classroom Faucet	Non-Potable	10/10/2020	510	Placarded for Non-Drinking Use Until Remediated
Room 209	Classroom Faucet	Non-Potable	10/10/2020	25	Placarded for Non-Drinking Use Until Remediated
Room 210	Classroom Faucet	Non-Potable	10/10/2020	74	Placarded for Non-Drinking Use Until Remediated
Room 207	Water Fountain-No Chiller	Potable	10/10/2020	21	Removed from Service, Pending Remediation
Room 208	Classroom Faucet	Non-Potable	10/10/2020	24	Placarded for Non-Drinking Use Until Remediated
Room 206	Classroom Faucet	Non-Potable	10/10/2020	140	Placarded for Non-Drinking Use Until Remediated
Room 206	Water Fountain-No Chiller	Potable	10/10/2020	26	Removed from Service, Pending Remediation
Playroom 3	Water Fountain-No Chiller	Potable	10/10/2020	67	Removed from Service, Pending Remediation

Jamaica Avenue School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Room 203	Water Fountain-No Chiller	Potable	10/10/2020	800	Removed from Service, Pending Remediation
Room 205	Classroom Faucet	Non-Potable	10/10/2020	69	Placarded for Non-Drinking Use Until Remediated
Room 204	Classroom Faucet	Non-Potable	10/10/2020	45	Placarded for Non-Drinking Use Until Remediated
Room 204	Water Fountain-No Chiller	Potable	10/10/2020	21	Removed from Service, Pending Remediation
Room 204	Classroom Faucet	Non-Potable	10/10/2020	440	Placarded for Non-Drinking Use Until Remediated
Men's Bathroom	Bathroom Faucet	Non-Potable	10/10/2020	48	Placarded for Non-Drinking Use Until Remediated
Women's Bathroom	Bathroom Faucet	Non-Potable	10/10/2020	90	Placarded for Non-Drinking Use Until Remediated
Women's Bathroom	Bathroom Faucet	Non-Potable	10/10/2020	54	Placarded for Non-Drinking Use Until Remediated
Women's Bathroom	Bathroom Faucet	Non-Potable	10/10/2020	250	Placarded for Non-Drinking Use Until Remediated
Women's Bathroom	Bathroom Faucet	Non-Potable	10/10/2020	52	Placarded for Non-Drinking Use Until Remediated
Room 201	Classroom Faucet	Non-Potable	10/10/2020	51	Placarded for Non-Drinking Use Until Remediated
Room 201	Water Fountain-No Chiller	Potable	10/10/2020	23	Removed from Service, Pending Remediation
Art Room	Hand Wash Only	Non-Potable	10/10/2020	170	Placarded for Non-Drinking Use Until Remediated
Room 203	Classroom Faucet	Non-Potable	10/10/2020	17	Placarded for Non-Drinking Use Until Remediated

John F. Kennedy High School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Room 224	Hand Wash Only	Non-Potable	10/8/2020	35	Placarded for Non-Drinking Use Until Remediated
Corridor Room 200-238	Water Fountain-No Chiller	Potable	9/22/2020	26	Removed from Service, Pending Remediation
Room 212 Inner Room	Hand Wash Only	Non-Potable	10/8/2020	27	Placarded for Non-Drinking Use Until Remediated
Corridor Room 200-238	Water Fountain-No Chiller	Potable	9/22/2020	18	Removed from Service, Pending Remediation
Girls Bathroom	Bathroom Faucet	Non-Potable	10/8/2020	17	Placarded for Non-Drinking Use Until Remediated
Girls Bathroom	Bathroom Faucet	Non-Potable	10/8/2020	50	Placarded for Non-Drinking Use Until Remediated
Math Dept. Room 207	Kitchen Faucet (Cold)	Potable	9/22/2020	120	Removed from Service, Pending Remediation
Corridor Room 120 To 130	Water Fountain-No Chiller	Potable	9/22/2020	32	Removed from Service, Pending Remediation
Art Room 161	Classroom Faucet	Non-Potable	10/8/2020	31	Placarded for Non-Drinking Use Until Remediated
Art Room 161	Classroom Faucet	Non-Potable	10/8/2020	27	Placarded for Non-Drinking Use Until Remediated
Art Room 161	Classroom Faucet	Non-Potable	10/8/2020	230	Placarded for Non-Drinking Use Until Remediated
Kitchen	Kitchen Faucet (Cold)	Potable	9/22/2020	140	Removed from Service, Pending Remediation
Guidance/Main Office Corridor	Water Fountain-No Chiller	Potable	9/22/2020	1900	Removed from Service, Pending Remediation

Old Bethpage Elementary School

Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Classroom 20B	Classroom Faucet	Non-Potable	10/6/2020	74	Placarded for Non-Drinking Use Until Remediated
Orchestra Room Bathroom	Bathroom Faucet	Non-Potable	10/6/2020	18	Placarded for Non-Drinking Use Until Remediated

Parkway Elementary School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Nurses Office Bathroom	Bathroom Faucet	Non-Potable	10/7/2020	36	Placarded for Non-Drinking Use Until Remediated
Principal's Office Bathroom	Bathroom Faucet	Non-Potable	10/7/2020	18	Placarded for Non-Drinking Use Until Remediated
Room 14	Water Fountain-No Chiller	Potable	10/7/2020	43	Removed from Service, Pending Remediation
Room 21	Classroom Faucet	Non-Potable	10/7/2020	63	Placarded for Non-Drinking Use Until Remediated
Main Corridor	Water Fountain-No Chiller	Potable	10/7/2020	18	Removed from Service, Pending Remediation

Pasadena Elementary School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Art Room	Water Fountain-No Chiller	Potable	10/9/2020	140	Removed from Service, Pending Remediation
Music Room	Classroom Faucet	Non-Potable	10/9/2020	700	Placarded for Non-Drinking Use Until Remediated
Music Room	Water Fountain-No Chiller	Potable	10/9/2020	23	Removed from Service, Pending Remediation

Plainview-Old Bethpage Middle School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Woodworking Room 101 Storage	Kitchen Faucet (Cold)	Potable	9/25/2020	18	Removed from Service, Pending Remediation
Women's Bathroom	Bathroom Faucet	Non-Potable	9/25/2020	41	Placarded for Non-Drinking Use Until Remediated
Room 300 Classroom	Classroom Faucet	Non-Potable	9/25/2020	22	Placarded for Non-Drinking Use Until Remediated
Room 309 Closet	Classroom Faucet	Non-Potable	9/25/2020	1000	Placarded for Non-Drinking Use Until Remediated
Room 309 Closet	Classroom Faucet	Non-Potable	9/25/2020	6600	Placarded for Non-Drinking Use Until Remediated
Art Room 223	Classroom Faucet	Non-Potable	9/25/2020	24	Placarded for Non-Drinking Use Until Remediated
Corridor Outside Room 231	Water Fountain-No Chiller	Potable	9/25/2020	25	Removed from Service, Pending Remediation
Room 202	Home Economics Faucet (Cold)	Potable	9/25/2020	32	Removed from Service, Pending Remediation
Room 204	Home Economics Faucet (Cold)	Potable	9/25/2020	620	Removed from Service, Pending Remediation
Pool Girls Locker	Bathroom Faucet	Non-Potable	9/25/2020	27	Placarded for Non-Drinking Use Until Remediated
Pool Girls Locker	Bathroom Faucet	Non-Potable	9/25/2020	29	Placarded for Non-Drinking Use Until Remediated
Pool	Water Fountain-No Chiller	Potable	9/25/2020	67	Removed from Service, Pending Remediation
Principal's Office Bathroom	Bathroom Faucet	Non-Potable	9/25/2020	17	Placarded for Non-Drinking Use Until Remediated
Room 312	Classroom Faucet	Non-Potable	9/25/2020	40	Placarded for Non-Drinking Use Until Remediated

Stratford Road Elementary School					
Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Girls Locker Room Bathroom	Bathroom Faucet	Non-Potable	10/3/2020	63	Placarded for Non-Drinking Use Until Remediated
Girls Locker Room Bathroom	Bathroom Faucet	Non-Potable	10/3/2020	21	Placarded for Non-Drinking Use Until Remediated
Room 215	Hand Wash Only	Non-Potable	10/3/2020	17	Placarded for Non-Drinking Use Until Remediated
School Psychologist	Hand Wash Only	Non-Potable	10/3/2020	61	Placarded for Non-Drinking Use Until Remediated
Recreation Room Bathroom	Bathroom Faucet	Non-Potable	10/3/2020	16	Placarded for Non-Drinking Use Until Remediated
Chorus Room 301/302 Book Storage Room	Hand Wash Only	Non-Potable	10/3/2020	17	Placarded for Non-Drinking Use Until Remediated
Custodial Room Bathroom	Bathroom Faucet	Non-Potable	10/3/2020	250	Placarded for Non-Drinking Use Until Remediated